

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST DOOR KEYPAD / CARD READER

SITE AND BLDG #: 69024-356

MECHANIC
SIGNATURE: [Signature]

DATE: 7/8/2022

LOCATION/RM #: _____ WO# _____ ASSET # _____

START TIME: _____ FINISH TIME: _____

ITEM	DESCRIPTION	TASK COMPLETE		NOTES / ACTIONS
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒	☐	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☐	
1	If applicable, test the controls for communications to the monitoring center. Inspect key pad for sticking keys and LED lights proper operation.	☒	☐	CLEAN KEY PAD HOUSING
2	Check power supplies. Clean keys and pad with a quick dry electrical cleaner. Wipe unit down	☒	☐	KEYPAD WORK FINE
3	Inspect and test the operation of device. -Observe unit in use	☒	☐	
4	Ensure proper protection of all visible wiring and conduits	☒	☐	
5	Verify that no compromise to devices has occurred (compromise of devices could be from building alterations, partitions, furniture or other obstacles) Any deficiencies found open a CM work order in Maximo and quote will be provided for CM repairs. Notate in note Column	☒	☐	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker

Additional Notes:
ASSET - W. 04
PM-54-9762-6808
PM-54-9763-6809