

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #: 104050 MECHANIC SIGNATURE: [Signature] DATE: 1-15-80

LOCATION/RM #: _____ START TIME: _____ FINISH TIME: _____

WO# _____ ASSET # _____

1		In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓			ASSET #10020 - light
2		Schedule and coordinate work with operating personnel.	✓			Don't work -
3		Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			They are all of it.
1		Open and tag switch.	✓			
2		Inspect visual condition of wiring. Look for evidence of overheating.	✓			
3		Check for proper light operation.	✓			
4		Test operation of automatic switches/ time clock/ photocells if applicable.	✓			yes
5		Inspect light pole and mounting devices for deficiencies.	✓			yes
6		For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250.00 per ticket.