

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PLUMBING FIXTURES

URINALS

SITE AND BLDG #: WY024-358

MECHANIC SIGNATURE: B. Malone

DATE: 7/12/19

LOCATION/RM #: WO# 4499 ASSET # 9295

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	MASKED TO	NOTES / ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	SPECIAL INSTRUCTIONS	
				YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
1	STANKS - Operate faucets, inspect for leaks, replace washers, "O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.	✓			
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.	✓			
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.	✓			
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.	✓			
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.	✓			
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.	✓	✓ No leaks Clean and inspect priorities		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Asset # W. O #
PM-4499 4499