

counter top Lavatory Auto Sensor
PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
 PLUMBING FIXTURES

SITE AND BLDG #:

12E

WO#

4110

ASSET #

10006

START TIME:

FINISH TIME:

MECHANIC SIGNATURE:

McNamee

DATE:

7/15/15

CHECK POINT	DESCRIPTION	NOTES		PAST ACTIONS (IF REPEATED DEFICIENCY, PROVIDE EXPLANATION)
		OK	NOT OK	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
1	SINKS - Operate faucets, inspect for leaks, replace washers/"O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO SERVICE
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	CLEAN PLUMBING FIXTURE
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: