

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**PLUMBING FIXTURES**

**SITE AND BLDG #:** UV 016

**MECHANIC SIGNATURE:** J. M. Lawrence

**DATE:** 7/16/19

**LOCATION/RM #:**

**WO#**

**ASSET #**

**START TIME:**

**FINISH TIME:**

CHECK POINT	CHECK/CONT'D DESCRIPTION	NOTES		IMPROVEMENTS/ACCTIONS
		NOTES	IMPROVEMENTS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
1	SINKS - Operate faucets, inspect for leaks, replace washers/"O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.			
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.			
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.			
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.			
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.			
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.			

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

**To be performed by:** General Maintenance Worker

**Additional Notes:**

ASSESSMENT — UV 016

PK-SU-0719-4244

PK-SU-10728-4253

PK-SU-10725-4250