

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PLUMBING FIXTURES

Showers

SITE AND BLDG #: UV 016 **MECHANIC SIGNATURE:** J. Hillman **DATE:** 7/23/19

LOCATION/RM #:	WO#	ASSET #	START TIME:	FINISH TIME:
CHECK POINT	CHECKPOINT DESCRIPTION	TESTED	TESTED	TESTED
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
1	SINKS - Operate faucets, inspect for leaks, replace washers/"O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.	<input checked="" type="checkbox"/>		
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.	<input checked="" type="checkbox"/>		
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.	<input checked="" type="checkbox"/>		
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.	<input checked="" type="checkbox"/>		
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.	<input checked="" type="checkbox"/>		
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker
Additional Notes:

A. J. J. H. - W. O. H.
PK-AW-10729-4254-12 pc showers
PK-AW-10733-4258-6 pc shower