

CABINET HEATER - FURNACE CHANGE

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
RADIANT BASEBOARDS/CONVECTORS (STEAM, HOT WATER, OR ELECTRIC)

SITE AND BLDG #: 24024-Bldg 356 MECHANIC SIGNATURE: Paul Daniels DATE: 8/5/2019  
LOCATION/RM #: EST 0120 ASSET # 9708 START TIME: \_\_\_\_\_ FINISH TIME: \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE, IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check radiator valve for free turning and seating. Check packing.	<input checked="" type="checkbox"/>		WAS HAIRY FINGER
2	Remove covers or wall panels. Note: Extreme care must be taken when removing marble or granite wall panels. These panels are extremely heavy and very fragile.	<input checked="" type="checkbox"/>		WAS FINGER
3	Check housing, braces, supports, hangers, and hardware for signs of deterioration or damage.	<input checked="" type="checkbox"/>		CLEAN CABINET HEATER
4	Check temperature or flow controls, shutoff valves, vents and traps for proper operation.	<input checked="" type="checkbox"/>		BLOWER-KNOCK
5	If radiator has automatic temperature regulating valve, remove valve cover and remove dirt by vacuuming.	<input checked="" type="checkbox"/>		
6	For hot water radiators, check air bleed valve.	<input checked="" type="checkbox"/>		
7	Wire brush and treat with rust inhibitor all rusted areas.	<input checked="" type="checkbox"/>		
8	Check coils, piping, and fin material for damage, leaks or looseness. Straighten finned material as necessary.	<input checked="" type="checkbox"/>		CHECK OK
9	Vacuum out finned tube area and interior housing.	<input checked="" type="checkbox"/>		
10	Clean and replace covers or wall panels and caulk wall panels as required. Clean work area.	<input checked="" type="checkbox"/>		CLEAN

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

WO # ASSET 14

2642 - PM - EST - 9708 #1

Page 1 of 1

PK - EST - 9708 #2

CABINET UNIT HEATER

PK - EST - 9708 #3

CABINET UNIT HEATER