

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #: X17024-208

MECHANIC SIGNATURE: Blalanes DATE: 3/8/2013

LOCATION/RM #: _____ WO# _____ ASSET # _____

START TIME: _____

FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Schedule and coordinate work with operating personnel.	<input checked="" type="checkbox"/>		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
10 MIN REQUIRED SPECIAL INSPECTION SERVICE				
1	Open and tag switch.	<input checked="" type="checkbox"/>		
2	Inspect visual condition of wiring. Look for evidence of overheating.	<input checked="" type="checkbox"/>		
3	Check for proper light operation.	<input checked="" type="checkbox"/>		
4	Test operation of automatic switches/ time clock/ photocells if applicable.	<input checked="" type="checkbox"/>		ok came in early
5	Inspect light pole and mounting devices for deficiencies.	<input checked="" type="checkbox"/>		yes
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

W.O# A-5856 #
2706 - PM-M6-9690
2708 - PM-M6-9691
2710 - PM-M6-9692