

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**LIGHTING, OUTSIDE**

**SITE AND BLDG #:** K-2029-357

**MECHANIC  
SIGNATURE:** M. H. Lane

**DATE:** 3/15/2019

**LOCATION/RM #:** WO# 2716   **ASSET #** 9766

**START TIME:**

**FINISH TIME:**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS</b> (IF TASK COMPLETE IS CHECKED, NO PROVIDE EXPLANATION)
		<b>YES</b>	<b>NO</b>	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Schedule and coordinate work with operating personnel.	<input checked="" type="checkbox"/>		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Open and tag switch.	<input checked="" type="checkbox"/>		
2	Inspect visual condition of wiring. Look for evidence of overheating.	<input checked="" type="checkbox"/>		
3	Check for proper light operation.	<input checked="" type="checkbox"/>		
4	Test operation of automatic switches/ time clock/ photocells if applicable.	<input checked="" type="checkbox"/>		
5	Inspect light pole and mounting devices for deficiencies.	<input checked="" type="checkbox"/>		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found

exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

*Assgt # 5766 → 2 lights out*