

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FILTER REPLACEMENT

SITE AND BLDG #: 24024-208

LOCATION/RM #: 260 WO# 7408

7410

MECHANIC
SIGNATURE: [Signature]

DATE: 3/3/2020

START TIME:

FINISH TIME:

1	Check, clean, and/or replace filters as required.	<u>✓</u>		
2	Initial and Date Filter (if disposable)	<u>✓</u>		
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSET #	SIZE	QTY		
<u>7611</u>	<u>Filter - 20x25x2</u>	<u>2</u>		<u>REPLACE</u>
	<u>20x20x2</u>	<u>4</u>		<u>REPLACE</u>
	<u>BELT</u>	<u>1</u>		<u>OK</u>
ASSET #				
<u>7613</u>	<u>Filter - 20x25x2</u>	<u>2</u>		<u>REPLACE</u>
	<u>Belt - 42360</u>	<u>1</u>		<u>REPLACE</u>
				<u>Check Air Hoses on</u>
				<u>lubricate motor</u>
				<u>& REPAIRING</u>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:

PKA-50-9611 - 7618
PKA-50-9613 - 7620