

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FILTER REPLACEMENT

SITE AND BLDG #: 14024-356

MECHANIC
SIGNATURE: *D. Williams*

DATE: 3/6/2020

LOCATION/RM #: 114B WO# 7421
7422

START TIME:

FINISH TIME:

		yes	no	
1	Check, clean, and/or replace filters as required.			
2	Initial and Date Filter (if disposable)	<i>✓</i>		
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSGT #	SIZ	QTY		
9703	FILTER - 12X25X2	41		REPLACE
	FILTER - 20X25X4	2		REPLACE
	BELT - AX52	1		ADJUST BELT
ASSGT #	FILTER -			
9704	FILTER -			REPLACE
	BELT			
ASSGT #	FILTER -			CHANG AIR HOPOVER OR IN
9705	FILTER -			WASH CARTRIDGES &
	BELT			13TARRIES

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:

~~ASSGT #~~~~WO #~~

PA-SA-9703-7635
PA-SA-9704-7636
PA-SA-9705-7637