

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: 24024 - 352

MECHANIC

SIGNATURE: M. Hansen

DATE: 3/13/202

LOCATION/RM #: WO# 2455 ASSET # 9755 START TIME:

FINISH TIME:

| Task | Completed | Notes |
|------|-------------------------------------|--|
| 1 | <input checked="" type="checkbox"/> | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instructions shall be strictly adhered to. |
| 2 | <input checked="" type="checkbox"/> | Schedule and coordinate work with operating personnel. |
| 3 | <input checked="" type="checkbox"/> | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. |
| 4 | <input checked="" type="checkbox"/> | 2 Buses out |
| 5 | <input checked="" type="checkbox"/> | Change in Energy |
| 6 | <input checked="" type="checkbox"/> | For any noted deficiency, takes pictures and open corrective maintenance ticket. |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

4 PC DOUBLE LIGHT POLE - 2 LAMPS OUT