

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

OVERHEAD EXHAUST FANS

SITE AND BLDG #: WY050

MECHANIC SIGNATURE: William

DATE: 3/8/2015

LOCATION/RM #: ROCK WO# 2725 ASSET # 10030

START TIME: _____ FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Schedule shutdown with operating personnel, as needed.	☒		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean unit, especially fan blades.	☒		
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	☒		Belt ok 4C-450
3	Perform required lubrication and remove old or excess lubricant.	☒		LUBRICATE + GREASE
4	Clean motor with vacuum or low pressure dry air (less than 40 psig). Check for obstructions in motor cooling and air flow.	☒		CLEAN FILTER - WASHABLE
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	☒		OK
6	Start unit and check for vibration and noise.	☒		
7	Remove all trash and debris.	☒		CLEAN

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: