

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**

**MECHANIC**  
**SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 19 - 20

**LOCATION/RM #:** Room 232 **WO#** 7675 **ASSET #** 190917-404

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**

**MECHANIC**  
**SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 19 - 20

LOCATION/RM #: Common area WO# 7675 ASSET #190917-405

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### Additional Notes:

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

### **VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**  
**LOCATION/RM #:** Common area **WO#** 7675 **ASSET #** 190917-40

**MECHANIC**  
**SIGNATURE:** Christopher N Pothier **DATE:** 3 - 19 - 20

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### Additional Notes:

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

### **VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**  
**LOCATION/RM #:** Common area **WO#** 7675 **ASSET #** 190917-40

**MECHANIC**  
**SIGNATURE:** Christopher N Pothier **DATE:** 3 - 19 - 20

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### Additional Notes:

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

### **VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**  
**LOCATION/RM #:** Common area **WO#** 7675 **ASSET #** 190917-40

**MECHANIC**  
**SIGNATURE:** Christopher N Pothier **DATE:** 3 - 19 - 20

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### Additional Notes:

These units are listed as heat pumps, but they are the same units as the VAVs.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**

**Common**  
**LOCATION/RM #:** area **WO#** 7675 **ASSET #**190917-409

**MECHANIC**

**SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 19 - 20

**START TIME:**

**FINISH TIME:**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS</b> (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

These units are listed as heat pumps, but they are the same units as the VAVs.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**

**Common**  
**LOCATION/RM #:** area **WO#** 7675 **ASSET #**190917-410

**MECHANIC**

**SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 19 - 20

**START TIME:**

**FINISH TIME:**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS</b> (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

### **VAV BOX**

**SITE AND BLDG #:** NY060 - 01 **Main Building**  
**LOCATION/RM #:** Common area **WO#** 7675 **ASSET #** 190917-41

**MECHANIC**  
**SIGNATURE:** Christopher N Pothier **DATE:** 3 - 19 - 20

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### Additional Notes:

These units are listed as heat pumps, but they are the same units as the VAVs.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VAV BOX**

**SITE AND BLDG #:** NY060 - 01    **Main Building**

**MECHANIC**  
**SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 19 - 20

**LOCATION/RM #:** Room 225 **WO#** 7675 **ASSET #** 190917-412

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS system permits, check that the operating controls activate damper per design specifications.	X		
2	If required, check damper linkage for tightness and lightly lubricate.	X		
3	If required, inspect dampers for free movement.	X		
4	If required, inspect actuators for tightness to mounting brackets.	X		
5	As needed, tighten electrical connections to servo motor.	X		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

These units are listed as heat pumps, but they are the same units as the VAVs.

## **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

### **MAKE UP AIR UNIT - HEATING/COOLING**

**SITE AND BLDG #:** NY060 - 01 **Main Building**

LOCATION/RM #: Roof top WO# 7675 ASSET #190917-346

MECHANIC  
SIGNATURE: Christopher N Pothier DATE: 3 - 9 - 20

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule shutdown with operating personnel.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check thermostat settings to ensure the cooling and heating systems operating correctly.	X		
2	Tighten all electrical connections and measure voltage and current on motors.	X		
3	Check filters and clean or replace as necessary.	X		
4	Lubricate all moving parts.	X		
5	Check and inspect the condensate drain in your central air conditioner, furnace and/or heat pump (when in cooling mode).	X		
6	Check controls of the system to ensure proper and safe operation. Check the starting cycle of the equipment to assure the system starts, operates, and shuts off properly.	X		
7	Clean evaporator and condenser air conditioning coils.	X		
8	Clean and adjust blower components to provide proper system airflow.	X		
9	Check all gas (or oil) connections, gas pressure, burner combustion and heat exchanger.		X	Unit does kitchen air flow and vent hood exhaust, no heating

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

### **Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**MAKE UP AIR UNIT - HEATING/COOLING**

**SITE AND BLDG #:** NY060 - 02      **Motor Pool**      **MECHANIC SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 17 - 20

**LOCATION/RM #:** Storage    **WO#** 7675    **ASSET #** 190917-371      **START TIME:**      **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule shutdown with operating personnel.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check thermostat settings to ensure the cooling and heating systems operating correctly.	X		
2	Tighten all electrical connections and measure voltage and current on motors.	X		
3	Check filters and clean or replace as necessary.	X		
4	Lubricate all moving parts.	X		
5	Check and inspect the condensate drain in your central air conditioner, furnace and/or heat pump (when in cooling mode).	X		
6	Check controls of the system to ensure proper and safe operation. Check the starting cycle of the equipment to assure the system starts, operates, and shuts off properly.	X		
7	Clean evaporator and condenser air conditioning coils.	X		
8	Clean and adjust blower components to provide proper system airflow.	X		
9	Check all gas (or oil) connections, gas pressure, burner combustion and heat exchanger.		X	This unit uses hot water, no gas or oil

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

This unit is double listed, it is also unit 10505

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**OUTDOOR CONDENSING UNIT**

**SITE AND BLDG #:** NY060 - 01 Main Building      **MECHANIC SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 18 - 20

**LOCATION/RM #:** Outside **WO#:** 7675 **ASSET #:** 190917-344      **START TIME:**      **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule outage of unit with personnel in area the unit serves.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Remove debris from air screen and clean underneath unit.	X		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X		
3	Straighten fin tubes with fin comb, as needed.	X		
4	Check electrical connections for tightness.	X		
5	Check mounting base for tightness.	X		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X		
7	Inspect all piping for leaks and tighten loose connections.	X		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	X		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		
11	Clean up work area.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:** This unit is listed as a mini-split, but it is the condensing unit for a mini-split unit.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**OUTDOOR CONDENSING UNIT**

**SITE AND BLDG #:** NY060 - 01 Main Building      **MECHANIC SIGNATURE:** *Christopher N Pothier* **DATE:** 3 - 18 - 20

**LOCATION/RM #:** Outside **WO#:** 7675 **ASSET #:** 190917-351      **START TIME:**      **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule outage of unit with personnel in area the unit serves.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Remove debris from air screen and clean underneath unit.	X		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X		
3	Straighten fin tubes with fin comb, as needed.	X		
4	Check electrical connections for tightness.	X		
5	Check mounting base for tightness.	X		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X		
7	Inspect all piping for leaks and tighten loose connections.	X		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	X		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		
11	Clean up work area.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:** This unit is listed as a mini-split, but it is the condensing unit for a mini-split unit.