

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

OUTDOOR CONDENSING UNIT

SITE AND BLDG #: NY128 - 02 **Motor Pool Building**

MECHANIC

SIGNATURE: *Christopher N Pothier* **DATE:** 3 - 20 - 19

LOCATION/RM #: Mech room **WO#** 2991 **ASSET #** 10866

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule outage of unit with personnel in area the unit serves.	X		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove debris from air screen and clean underneath unit.	X		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X		
3	Straighten fin tubes with fin comb, as needed.	X		
4	Check electrical connections for tightness.	X		
5	Check mounting base for tightness.	X		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X		
7	Inspect all piping for leaks and tighten loose connections.	X		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	X		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		
11	Clean up work area.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes: