

EXIT LIGHTS

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TIME CLOCK, LIGHTING

SITE AND BLDG #: NY024 - BLDG 356MECHANIC
SIGNATURE: [Signature]DATE: 5/9/2019
FINISH TIME: 5/10/2019

LOCATION/RM #: _____ WO# _____ ASSET # _____

START TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<u>Y</u>			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<u>Y</u>			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	<u>Y</u>			<u>CLEAN EXIT LIGHTS</u>
2	Check physical connections.	<u>Y</u>			<u>FIX WIRING.</u>
3	Verify the timeclock configuration, ensure proper operation.	<u>Y</u>			
4	If applicable, check battery and replace as needed.	<u>Y</u>			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

WO # ASSET #
3646 — PM-27-9760