

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

TIME CLOCK, LIGHTING

SITE AND BLDG #: NY060 - 02 Motor Pool

MECHANIC SIGNATURE: *Christopher N Pothier* **DATE:** 5 - 22 - 19

LOCATION/RM #: Electrical rmWO# 3529 **ASSET #** 10536

START TIME: **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	X		
2	Check physical connections.	X		
3	Verify the timeclock configuration, ensure proper operation.	X		
4	If applicable, check battery and replace as needed.		X	unit is hard wired

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: