

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST TIME CLOCK, LIGHTING

SITE AND BLDG #: 44024-358 MECHANIC SIGNATURE: Pullano DATE: 11/3/15
LOCATION/RM #: 1300 WO# 11 ASSET # 11 START TIME: FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒	☐		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☐		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	☒	☐		CLEAN EXIST LIGHT
2	Check physical connections.	☒	☐		FIXTURES
3	Verify the timeclock configuration, ensure proper operation.	☒	☐		
4	If applicable, check battery and replace as needed.	☒	☐		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

ASSET # - W. 04

PM-WT-9809-55557 EXIST LIGHT OK
PM-WT-9810-55558