

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

11-19-2018

POVEMBER
CUTTER

SITE AND BLDG #: 14050-00001

MECHANIC SIGNATURE: *[Signature]* DATE: 11-19-2018

LOCATION/RM #: WO# ASSET # 10019 / 10020

START TIME: 2:30 PM FINISH TIME: 3:00 PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Schedule and coordinate work with operating personnel.	/		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		X	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.		X	
2	Inspect visual condition of wiring. Look for evidence of overheating.			
3	Check for proper light operation.	/		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		X	
5	Inspect light pole and mounting devices for deficiencies.	/		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PAK-NO - ASSET # 10019 - DOUBLE FOOD UCITY POLE MOUNTED
PAK-NO - ASSET # 10020 - DOUBLE FOOD UCITY POLE MOUNTED