

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST DOMESTIC HOT WATER HEATER - ELECTRIC

SITE AND BLDG #: 24116-01 MECHANIC SIGNATURE: [Signature] DATE: 11/27/2018
LOCATION/RM #: WO# 1141 ASSET # 10739 START TIME: 12:30 PM FINISH TIME: 12:45 PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ACTIONS	
		YES	NO		(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/				
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Attach drain hose. Drain several gallons from tank to remove sediment.	X				
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	/				
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections.	/				
4	Check operation/ setting of aquastat. Check hot water temperature with dial thermometer, set aquastat at minimum value required for all uses.	/				
5	Check amperage draw of upper and lower elements and compare to name plate data.	X				
6	Clean element contacts, and check for proper closing under load.	X				
7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing, and replace as required.	/				
8	If applicable, Remove and inspect Anode, replace if necessary	X				
9	Clean up work area and remove trash.	/				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: