

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OIL WATER SEPARATOR

SITE AND BLDG #: Wyo 116LOCATION/RM #: 5653ASSET # 10781WO# 5653START TIME: 10/17/15FINISH TIME: 10/17/15MECHANIC
SIGNATURE: R. W. Lohr DATE: 10/17/15

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	OIL LAYER - If possible, measure the surface oil layer in the oil water separator and record depth.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	CLEAN O/C TANK
2	SOLID ACCUMULATION - If possible, measure the solid accumulation in the bottom of the oil water separator and record.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	REMOVE DIRT & GRESSE
3	Recommend whether oil water separator needs to be cleaned.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	RECOMMEND

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: