

Part 2 of 2

| Argent Inspections  |                                |                  |  |                    |  |
|---|--------------------------------|------------------|--|--------------------|--|
| Pressure Vessel Inspection Certificate  |                                |                  |  |                    |  |
| Expiration Date   | Inspection Date                | National Board # | Pressure Allowed   | Capacity           |  |
| 10/20/2023  | 10/20/2020                     | 1065541          | 200 PSI  | 20 cu ft           |  |
| Customer<br>99th R5Z2 MD002 Usarc Curtis Bay  |                                |                  | Manufacturer<br>Melben   | Year Built<br>2017 |  |
| Location/Building #<br>OMS  |                                | Serial #         |  | Property #         |  |
| Inspection Type(s) Performed  |                                |                  | Vessel Type  |                    |  |
| <input checked="" type="checkbox"/> External <input checked="" type="checkbox"/> Internal<br><input checked="" type="checkbox"/> Operational <input checked="" type="checkbox"/> Pressure |                                |                  | <input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave<br><input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water<br><input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen<br><input type="checkbox"/> Other |                    |  |
| Commission #<br>13314   | Inspector:<br>Craig H. Bennett |                  |    |                    |  |
| Signature   |                                |                  |  |                    |  |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED Vessel

## Argent Inspections

Form AI-09

### Pressure Vessel Inspection Certificate

|  |                                |  |                             |                           |
|--|--------------------------------|--|-----------------------------|---------------------------|
| Expiration Date<br>10/20/2023  | Inspection Date<br>10/20/2020  | National Board #<br>69722  | Pressure Allowed<br>200 psi | Capacity<br>25 cubic feet |
| Customer<br>99th RSC R5 Z2 MD002 USARC Curtis Bay  |                                | Manufacturer<br>Steel Fabricators  | Year Built<br>2012          |                           |
| Location/Building #<br>OMS Bldg 4  |                                | Serial #   | Property #                  |                           |
| Inspection Type(s) Performed   |                                | Vessel Type  |                             |                           |
| <input checked="" type="checkbox"/> External <input checked="" type="checkbox"/> Internal<br><input checked="" type="checkbox"/> Operational <input type="checkbox"/> Pressure |                                | <input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave<br><input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water<br><input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen<br><input type="checkbox"/> Other |                             |                           |
| Commission #<br>13314  | Inspector:<br>Craig H. Bennett |  |                             |                           |
| Signature<br><i>Craig Bennett</i>  |                                |  |                             |                           |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED Vessel

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate

|   |                                |  |   |                               |
|---|--------------------------------|--|---|-------------------------------|
| Expiration Date<br>10/21/2021   | Inspection Date<br>10/21/2020  | Next Watersides/Firesides<br>2023/2021   | Next Strength Test<br>0   | National Board #<br>107020    |
| Customer<br>99th RSC R5 Z2 MD019 USARC Owing Mills  |                                | Manufacturer<br>Fulton   | Year Built<br>Unknown   |                               |
| Building #<br>Boiler Room   |                                | Serial #<br>None   | Property #<br>HWB-1   | Jurisdiction #<br>Asset# 8185 |
| Pressure Allowed<br>30 psi  | Capacity<br>675,000 BTU/HR     | Safety Valves<br>1   | Programmer Mfr<br>Honeywell   | Burner Mfr<br>Fulton          |
| Inspection Type(s) Performed  |                                |  | Fuel Type(s) Certified to Use   |                               |
| <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides<br><input checked="" type="checkbox"/> External/Operational<br><input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness |                                |  | <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas<br><input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood<br><input type="checkbox"/> Heavy Fuel Oil |                               |
| Commission #<br>13314   | Inspector:<br>Craig H. Bennett | <br><small>POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER</small> |   |                               |

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate

|  |                                |  |  |                               |
|--|--------------------------------|--|--|-------------------------------|
| Expiration Date<br>10/21/2021  | Inspection Date<br>10/21/2020  | Next Watersides/Firesides<br>2023/2020 | Next Strength Test<br>0  | National Board #<br>107143    |
| Customer<br>99th RSC R5 Z2 MD019 USARC Owing Mills   |                                | Manufacturer<br>Fulton                 | Year Built<br>Unknown  |                               |
| Building #<br>Boiler Room  |                                | Serial #<br>None                       | Property #<br>HWB-2  | Jurisdiction #<br>Asset# 8186 |
| Pressure Allowed<br>30 psi   | Capacity<br>675,000 BTU/HR     | Safety Valves<br>1                     | Programmer Mfr<br>Honeywell  | Burner Mfr<br>Fulton          |
| Inspection Type(s) Performed<br><input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides<br><input checked="" type="checkbox"/> External/Operational<br><input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness |                                |  | Fuel Type(s) Certified to Use<br><input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas<br><input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood<br><input type="checkbox"/> Heavy Fuel Oil |                               |
| Commission #<br>13314  | Inspector:<br>Craig H. Bennett | Signature                              | <i>Craig Bennett</i>   |                               |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate

|   |                                |  |   |                               |
|---|--------------------------------|--|---|-------------------------------|
| Expiration Date<br>10/31/2020   | Inspection Date<br>10/31/2019  | Next Watersides/Firesides<br>2020/2020 | Next Strength Test<br>0   | National Board #<br>107140    |
| Customer<br>99th RSC R5 Z2 MD019 USARC Owing Mills  |                                | Manufacturer<br>Fulton                 | Year Built<br>Unknown   |                               |
| Building #<br>Boiler Room   |                                | Serial #<br>None                       | Property #<br>HWB-3   | Jurisdiction #<br>Asset# 8187 |
| Pressure Allowed<br>30 psi  | Capacity<br>675,000 BTU/HR     | Safety Valves<br>1                     | Programmer Mfr<br>Honeywell   | Burner Mfr<br>Fulton          |
| Inspection Type(s) Performed  |                                |  | Fuel Type(s) Certified to Use   |                               |
| <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides<br><input checked="" type="checkbox"/> External/Operational<br><input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness |                                |  | <input type="checkbox"/> Coal<br><input type="checkbox"/> Light Fuel Oil<br><input type="checkbox"/> Heavy Fuel Oil<br><input checked="" type="checkbox"/> Natural Gas<br><input type="checkbox"/> Wood |                               |
| Commission #<br>13314   | Inspector:<br>Craig H. Bennett | Signature                              | <i>Craig Bennett</i>  |                               |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER

# Argent Inspections

## Form AI-08

### Boiler Inspection Certificate

|   |                                |  |  |                              |
|---|--------------------------------|--|--|------------------------------|
| Expiration Date<br>10/19/2021   | Inspection Date<br>10/19/2020  | Next Watersides/Firesides<br>2022/2021   | Next Strength Test<br>0  | National Board #<br>CA3DE001 |
| Customer<br>99th R5Z2 DE001 USARC Dover   |                                | Manufacturer<br>Bosch  | Year Built   |                              |
| Building #  |                                | Serial #<br>2530-203-30004-7747014551  | Property #   | Jurisdiction #               |
| Pressure Allowed<br>50 psi  | Capacity<br>881,000 BTU/HR     | Safety Valves<br>1   | Programmer Mfr<br>Bosch  | Burner Mfr<br>Bosch          |
| Inspection Type(s) Performed<br><input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides<br><input checked="" type="checkbox"/> External/Operational<br><input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness |                                |  | Fuel Type(s) Certified to Use<br><input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas<br><input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood<br><input type="checkbox"/> Heavy Fuel Oil |                              |
| Commission #<br>13314   | Inspector:<br>Craig H. Bennett | Signature  |  |                              |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER

| Argent Inspections  |                                |  |  |                         |                              |
|---|--------------------------------|--|--|-------------------------|------------------------------|
| Boiler Inspection Certificate   |                                |  |  |                         |                              |
| Expiration Date<br>10/20/2022   | Inspection Date<br>10/20/2020  | Next Watersides/Firesides<br>2021/2021   |  | Next Strength Test<br>0 | National Board #<br>173590   |
| Customer<br>99th RSC R5 Z2 MD002 USARC Curtis Bay   |                                |  | Manufacturer<br>Lochinvar  |                         | Year Built<br>2010           |
| Building #<br>Boiler Room   |                                | Serial #<br>K10H10173590   |  | Property #<br>Blr-1     | Jurisdiction #<br>Asset 1801 |
| Pressure Allowed<br>160 psi   | Capacity<br>500,000 BTU/HR     | Safety Valves<br>1   | Programmer Mfr<br>Lochinvar  | Burner Mfr<br>Lochinvar |                              |
| Inspection Type(s) Performed<br><input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides<br><input checked="" type="checkbox"/> External/Operational<br><input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness |                                |  | Fuel Type(s) Certified to Use<br><input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas<br><input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood<br><input type="checkbox"/> Heavy Fuel Oil |                         |                              |
| Commission #<br>13314   | Inspector:<br>Craig H. Bennett | Signature  |  |                         |                              |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER