


## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>10/4/2020</b>	Inspection Date 10/4/2019	Next Watersides/Firesides 2023/2020	Next Strength Test 0	National Board # CI-1NY059
Customer USARC Rotterdam NY059		Manufacturer Weil McLain	Year Built	
Building # Boiler Room		Serial #	Property # B-1	Jurisdiction # Asset 10369
Pressure Allowed 50 psi	Capacity 2,452,000 BTU/HR	Safety Valves 1	Programmer Mfr Honeywell	Burner Mfr Power Flame
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13314	Inspector: Craig H. Bennett	Signature 		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*