

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date 9/14/2020	Certificate Issued Yes	Expiration Date 9/14/2021	Prepared for Inspection Yes	Next Watersides/Firesides 2023/2021	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R2 Z1 NY024 USARC Staten Island			Boiler Location Name and/or Building Number Bldg 356		
Address 356 Battery Rd			Boiler Location Address		
City Staten Island		State NY	Zip 10305	City	
National Board # 13934	Jurisdiction # Asset# 9727	Property # #2	Boiler Use Closed Heating Loop		Fuel Type Natural Gas
Manufacturer Triad		Model # GPS-900-SH		Serial # 58054	Year Built 2011
Capacity 900,000 BTU/HR	Design Pressure 125 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Honeywell		Burner Manufacturer Power Flame
Number of Safety Valves 1	Combustion Efficiency % CO2	ppm CO	% Excess O2		Flue Gas Temperature Degrees F
Valve 1	Valve Manufacturer Watts	Size 3/4"	Set Pressure 50 psi	Capacity 950,000 BTU/HR	Lift Pressure Hand
Valve 2					Reseat Pressure Sat
Valve 3:					
Valve 4:					
Safety Devices Tested Internal Flame Scanner, Low Gas Pressure Switch, High Gas Pressure Switch, Low Water Level Control (Electrically), Combustion Air Switch, Operating Temperature Control, High Temperature Lockout, and Remote Emergency Disconnect. The safety valve was lifted by hand per NBIC Part 2 Sec 2.5.7.e. It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification					
Comments This Hot Water Heating Boiler was inspected per UFC 3-430-07, ASME CSD-1, and the National Board Inspection Code. Light scale observed on watersides of tubes, and light debris observed on firesides, and no evidence of leakage with hydrostatic pressure of 30 psi on watersides of boiler. All safety devices tested functioned properly during the inspection process. Please install CO monitor/alarm as required by NBIC 2019 prior to next inspection.					
Inspector Commission 13373	Inspector Dale Brooks	Signature <i>Dale A. Brooks</i>			
Attachments Yes 1 Pages	Technical Manager Jerry Kuykendall	Signature <i>Jerry Kuykendall</i>			