

# February checklist 2023

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

### EMERGENCY EXIT SIGNS AND WALL PACKS

ny024

**ACTIVITY AND BLDG #:****MECHANIC  
SIGNATURE:** Ramon V**DATE:** 2-2-2023**LOCATION/RM #:** WO# 20926    **ASSET #** 9693**START TIME:****FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Inspect for structural defects, note needed repairs			
2	Push test buttons and observe light operation. Note any units that do not operate properly.			
3	Clean exterior with dry cloth.			
4	For Exit lights check for proper arrow direction.			
5	Make and/or recommend any needed repairs.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**