

## April checklist 2022

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
VAULT DOOR

SITE AND BLDG #: ny116

118 16712 10761  
LOCATION/RM #: 117 WO# 16713 ASSET# 10762

MECHANIC SIGNATURE: Ramon V

DATE: 4-21-2022

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Review manufacturer's instructions.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check alignment of dial ring with lock case; correct if necessary.	✓		
2	Check mounting screws of dial ring and lock case; tighten them, using a thread locking compound.	✓		
3	Look for corrosion or presence of any foreign matter that will in any manner affect the lock's proper operation.	✓		
4	Look for any signs of malfunctioning or impending failure.	✓		
5	Look for any signs of tampering, forced, or covert entry; report this to the local Security and Law Enforcement Office.	✓		
6	Check Alignment of door with frame	✓		
7	Check for difficulty in opening, closing or locking the door.	✓		
8	Replace all defective hardware	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

1. A qualified locksmith with expertise in GSA locks is required.
2. Prior Coordination with the facility must occur prior to scheduled work. (See suggested coordination questions below)
  - a. Access to Arms room is accompanied. Someone with unaccompanied access MUST be present at all times during scheduled work.
  - b. Coordination AND approval from the Facility Coordinator or Physical Security Officer or PIN Custodian for combination change.

Additional Notes:

## Vault preventive maintenance