

May checklist 2022

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST REACH-IN REFRIGERATORS/ FREEZERS

SITE AND BLDG #:	ny116	17037	10692	MECHANIC SIGNATURE:	Ramon V
LOCATION/RM #:	122A	17039	10694	DATE:	5-12-2022
WO#	17040	10695		START TIME:	
ASSET #	17041	10696		FINISH TIME:	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	✓			
2	Verify indicator light on; check compartment temperature.	✓			
3	Examine evaporator for proper clearances/slope and air flow.	✓			
4	Examine handles, hinges and tightness of door closure.	✓			
5	Examine safety door release and fan shut down safety switch.	✓			
6	Inspect lighting for burnt out lamps.	✓			
7	Check starter panels and controls for proper operation, burned or loose contacts, and loose connections.	✓			
8	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).	✓			
9	Clean condenser coil and condensing unit section.	✓			
10	Clean and inspect defrost evaporation trays/pans.	✓			
11	Inspect defrost systems for proper operation, including timer; adjust as required. Have automatic defrosters adjusted as required so freezer will defrost during "Off Peak" hours	✓			
12	Check operation of thermostats; calibrated as required.	✓			
13	Check coil superheat and adjust to manufacturers recommendations.	✓			
14	Inspect and service all electric motors.	✓			
15	Inspect door gaskets for damage and proper fit; adjust gaskets as required and lubricate hinges with food grade oil.	✓			
16	Check door gasket heater.	✓			
17	Check box floor for water or ice accumulation.	✓			
18	Check box for excessive ice build- up and open seams.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

no longer use

Additional Notes: