

## September checklist 2022

### PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

#### FILTER REPLACEMENT

18856  
19079  
18857

MECHANIC SIGNATURE: **Ramon V**

DATE: 9-7-2022

LOCATION/RM #: WO# 19080

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check, clean, and/or replace filters as required.	✓		
2	Initial and Date Filter (if disposable)	✓		
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓		
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
10647	pre filter 24x24x2	6	replace	
10647	final filter 24x24x6	6	replace	
10648	pre filter 24x24x2	6	replace	
10648	final filter 24x24x6	6	replace	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

### **Additional Notes:**