

August checklist 2023
PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #:	ny116	23459	1L-02	MECHANIC SIGNATURE:	Ramon V
		23460	1L-03		DATE: 8-16-2022
LOCATION/RM #:	WO#	23461	ASSET#	1L-04	START TIME: FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				Asset 1L-04 missing asset no bldg 4
2	Schedule and coordinate work with operating personnel.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Open and tag switch.				
2	Inspect visual condition of wiring. Look for evidence of overheating.				
3	Check for proper light operation.				
4	Test operation of automatic switches/ time clock/ photocells if applicable.				
5	Inspect light pole and mounting devices for deficiencies.				
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: