

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #:

MECHANIC SIGNATURE:

DATE:

LOCATION/RM #:114

WO# 10113

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.			
2	Initial and Date Filter (if disposable)			
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSET #	SIZE	QTY		NOTES/ ACTIONS
10652				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: