

Date: 6/27/2023

Region: 4A
FAC ID: NY126

CSS No.: 93780
Maximo WO No.: 13359

Asset #: 3221

Priority: Urgent



Original Work Request:

Repair chiller circuit #2. Chiller circuit #1 was able to be repaired however circuit #2 is still not running.

Description of Repairs Needed:

Labor and material to a.) perform leak search on stage one cooling b.) repair leak if possible c.) evacuate system and recharge with refrigerant R-410A. d.) Troubleshoot second circuit, replace motor proector and check for proper operation

Labor:

	Labor Hrs	Labor Rate	Total
Technician	8	\$ 115.00	\$ 920.00
Assistant Technician	8	\$ 90.00	\$ 720.00

Material List:

	Quantity	Cost	Total
Refrigerant R410A	86	\$ 23.47	\$ 2,018.42
Refrigeration Fee	1	\$ 180.00	\$ 180.00
Leak Detection	1	\$ 30.00	\$ 30.00
Misc. Hardware	1	\$ 138.60	\$ 138.60
Motor Protector	1	\$ 363.33	\$ 363.33
Trip Charge	1	\$ 98.00	\$ 98.00

Equipment List:

	Quantity	Cost	Total
		\$ -	\$ -
		\$ -	\$ -
		\$ -	\$ -

PM WO History:

12682

Estimate Summary:

Labor	Material	Equipment
\$1,640.00	\$2,828.35	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$4,468.35	\$536.20	\$268.10	\$5,272.65