

W.O. #2341 ASSET #7207

WV 053-02 - Joe Nurie Lane CSS #11522
(REBUILD/RETEST)

INSPECTION REPORT FOR CROSS-CONNECTION AND BACKFLOW-PREVENTION ASSEMBLY

Name of Owner: US ARMY

Mailing Address: Street: 109 Joe Nurie Lane

City, State, Zip _____

Name of Premises: US ARMY BASE

Street Address: Street: 109 Joe Nurie Lane

City, State, Zip WHEELING, WV 26003

Location of Assembly: Boiler Room Installation Date: ?

Type of Assembly: RP2 Manufacturer: Wilkins/Zurn Size: 1"

Model Number: 975XL Serial Number: WD42912

Meter Number Associated with above Backflow Preventor: 11 001263

Tested by (Firm Name): CMI MGT, INC. / FRANCIS SAPIENZA


Business Address: Street: _____

City, State, Zip _____

Telephone No. _____

Date of Initial Test: 2-2-18 Passed: _____ Failed: Date of Retest: _____

I certify that I have tested the above assembly and that it meets the performance requirements



(Signature of Licensed Tester)

ASSET #30207

(License Number of Tester)

Line Pressure at Time of Test 45 psi

	CHECK VALVE 1	CHECK VALVE 2	DIFFERENTIAL PRESSURE RELIEF VALVE
Initial Test	1. Leaked _____ psid 2. Closed Tight _____	1. Leaked _____ psid 2. Closed Tight _____	1. Opened at _____ psid reduced pressure 2. Did not Open _____
R	Cleaned: Replaced: Disc Spring Guide Pin Retainer Hinge Pin Seat Diaphragm Other, describe	Cleaned: Replaced: Disc Spring Guide Pin Retainer Hinge Pin Seat Diaphragm Other, describe	Cleaned: Replaced: Disc Spring Guide Pin Retainer Hinge Pin Seat Diaphragm Other, describe
E			
P			
A			
I			
R			
S			
Final Test	RP _____ psid Closed Tight _____	Closed Tight _____	Open at _____ psid reduced pressure

Remarks: Relief valve is steadily dripping, 0 psi on TEST #1,
UNIT FAILS INSTANTLY