

CMI Management Inc.

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXHAUST FANS

SITE AND BLDG #: WV006 **see**
LOCATION/RM #: WO# 20709 **ASSET #** below **MECHANIC SIGNATURE:** Brian McDaniel **DATE:** 12-9-2025
START TIME: 800 **FINISH TIME:** 530

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean unit, especially fan blades.	<input checked="" type="checkbox"/>		
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	<input checked="" type="checkbox"/>		
3	Perform required lubrication and remove old or excess lubricant.	<input checked="" type="checkbox"/>		Assets-9102,9105,9106
4	Clean motor with vacuum or low pressure dry air (less than 40 psig). Check for obstructions in motor cooling and air flow.	<input checked="" type="checkbox"/>		
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	<input checked="" type="checkbox"/>		
6	Start unit and check for vibration and noise.	<input checked="" type="checkbox"/>		
7	Remove all trash and debris.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

