

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR CONDITIONER - WINDOW UNIT

MECHANIC
SIGNATURE

Brian M. [Signature]

DATE: 6-5-2025

SITE AND BLDG #: **wv006-2**

LOCATION/RM #: **WO# 18909 ASSET # 9161**

START TIME: _____ FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean filter as needed			
2	Check operating temperature.			
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.			
4	Inspect motor for excessive heat, noise, and vibration			
5	Clean condener and evaporator coils and blower.			
6	Inspect for rust and corrosion.			
7	Inspect unit for proper operation. Ensure unit it securely mounted in window.			
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker **No Access motor pool is under construction**