

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OIL WATER SEPARATOR**

SITE AND BLDG #: WV024

MECHANIC SIGNATURE: Brian Mcderment **DATE:** 9-2-2025

LOCATION/RM #: WO# 20043 ASSET # 9253

START TIME: 8:00 **FINISH TIME:** 330

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	OIL LAYER - If possible, measure the surface oil layer in the oil water separator and record depth.	●		
2	SOLID ACCUMULATION - If possible, measure the solid accumulation in the bottom of the oil water separator and record.	●		
3	Recommend whether oil water separator needs to be cleaned.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: