

99th RSC Region 5, Zone Inventory

Key: Black - Current, Blue - Due, Red - Failed, Yellow - Added to Contract, Grey - Removed from Contract

DE001 USARC Dover

344 North New St. Dover, DE 19904

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1	Boiler	Bosch	SN	2530-203-300017-7747014551	11/4/2019	Yes	11/4/2020	
2	Boiler	Bosch	SN	2530-203-300002-7747014551	11/4/2019	Yes	11/4/2020	
3	Boiler	Bosch	SN	2530-203-300004-7747014551	11/4/2019	Yes	11/4/2020	
	Air Receiver	DeVilbiss	NB	137508	11/4/2019	Yes	11/4/2022	

DE002 USARC/AMSA Cape Henlopen

1137 Savannah Rd. Lewes, DE 19958

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1	Boiler	Weil-McLain	SN	Cast Al 1 DE002	11/4/2019	Yes	11/4/2020	
2	Boiler	Weil-McLain	SN	Cast Al 2 DE002	11/4/2019	Yes	11/4/2020	
	Air Receiver	Twin Lakes Tanks	NB	2062400	11/4/2019	Yes	11/4/2022	

DE007 AFRC Newark

1001 Ogletown Rd. Newark, DE 19711

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1731 (B-1)	Boiler	Fulton	NB	110930	11/1/2019	Yes	11/1/2020	
1732 (B-2)	Boiler	Fulton	NB	109874	11/1/2019	Yes	11/1/2020	
	Air Receiver	Steel Fab	NB	4042	11/1/2019	Yes	11/1/2022	

MD002 USARC Curtis Bay

700 E. Ordnance Rd. Baltimore, MD 21226

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1801 (Boiler 1)	Boiler	Lochinvar	NB	173590	10/30/2019	Yes	10/30/2020	Add e-stop at second exit.
1802 (Boiler 2)	Boiler	Lochinvar	NB	173566	10/30/2019	Yes	10/30/2020	Add e-stop at second exit.
	Air Receiver	Steel Fab	NB	69722	10/31/2019	No		Improperly installed.
	Air Receiver							Couldn't access

MD003 USARC Liberty Heights

5515 Liberty Heights Ave. Baltimore, MD 21207

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1860 (Boiler 1)	Boiler	Bosch	SN	2630-012-300014-7747014550	10/31/2019	No		Install E-Stop.
1861 (Boiler 2)	Boiler	Bosch	SN	2530-012-300015-7747014350	10/31/2019	No		Install E-Stop.
1862 (Boiler 3)	Boiler	Bosch	SN	2530-012-300005-7747014550	10/31/2019	No		Install E-Stop.
OMS	Boiler	Bosch	SN	2530-010-300007-7797014548	10/31/2019	No		Repair/replace makeup water check valve, can't light.

MD005 USARC Jecelin

1900 Broening Hwy. Baltimore, MD 21224

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
1	Boiler	Bosch	SN	2530-104-300005-7747024549		No		Plant shut down w/ water disconnected
2	Boiler	Bosch	SN	2530-104-300012-7747014549		No		Plant shut down w/ water disconnected
3	Boiler	Bosch	SN	2530-107-300014-7747014549		No		Plant shut down w/ water disconnected

MD019 USARC Owings Mills

12100 Greenspring Ave. Owings Mills, MD 21117

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
8185 (HWB-1)	Boiler	Fulton	NB	107020	10/31/2019	Yes	10/31/2020	
8186 (HWB-2)	Boiler	Fulton	NB	107143	10/31/2019	Yes	10/31/2020	
8187 (HWB-3)	Boiler	Fulton	NB	107140	10/31/2019	Yes	10/31/2020	
	Air Compressor	Champion						Couldn't access.

MD024 AMSA Curtis Bay

720 E. Ordnance Rd. Baltimore, MD 21226

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
	Air Receiver	Manchester	NB	1559060	10/30/2019	Yes	10/30/2022	

MD048 USARC Abingdon

1309 Continental Dr. Abingdon, MD 21009

Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes
	None							